


**CONTROL CARD RACK FRONT VIEW**

(FOR REAR CONNECTION DETAILS, REFER TO DWG NO. SS66100-12 SHT 2 OF 2)


**STANDARD CARD RACK**

- STANDARD 19" RACK MOUNTING, EURORACK SIZE 3U HEIGHT
- RUGGED CONSTRUCTION
- CONTAINS MAXIMUM 17 CARDS (INCLUDING 1 ANNUNCIATOR CARD)
- CONFORMS TO IEC PUBLICATION 297 EDITION 2 AND DIN 41494
- BASEFFA APPROVED EXD FLAMEPROOF ENCLOSURES CAN BE PROVIDED FOR RACK MOUNTING


|  |          |                            |       |            |
|--|----------|----------------------------|-------|------------|
| REV. DATE  |          | DESCRIPTION                | DRAWN | CHECK'D    |
| 0  | 11.12.92 | ISSUED FOR APPROVAL        | SA    | AD         |
| 1  | 24.07.98 | REVISED DETAIL, TRK & DATA | SA    | AD         |
| <p>HEAD OFFICE : SEAGULL SAFETY LTD<br/>45 CHESTNUT AVENUE<br/>WOKINGHAM, BERKSHIRE<br/>RG41 3HW, ENGLAND UNITED KINGDOM<br/>Tel: 44-118-978 3978 Fax: 44-118-977 5261</p> <p>REGIONAL OFFICE : SEAGULL SAFETY (S) PTE LTD<br/>1 GENTING LINK<br/>PERFECT INDUSTRIAL BUILDING<br/>SINGAPORE 349518<br/>Tel: (65) 6-747 9646 Fax: (65) 6-744 4028</p> |          |                            |       |            |
| <p>THIS IS THE PROPERTY OF SEAGULL SAFETY LTD AND IS ONLY ISSUED ON CONDITION THAT NO COPY IS TAKEN OR REPRODUCTION OR DISCLOSURE TO A THIRD PARTY EITHER WHOLLY OR IN PART IS MADE WITHOUT THE WRITTEN CONSENT OF SEAGULL SAFETY LTD.</p>   |          |                            |       |            |
| <p>DWG NO : SS66100-12 (SHT 1 OF 2)</p>  |          |                            |       |            |
| DRAWN BY   |          | SA                         | DATE  | 11.12.1992 |
| CHECKED BY   |          | AD                         | DATE  | 11.12.1992 |
| <p>STANDARD 19" RACK<br/>SS814-R</p>   |          |                            |       |            |
| <p>REVISION</p>  |          |                            |       |            |




**GAS DETECTOR TERMINALS**



**FIRE DETECTOR TERMINALS**



**COMMON RACK TERMINALS (A)**



HEAD OFFICE :

**SEAGULL SAFETY LTD**

45 CHESTNUT AVENUE  
WOKINGHAM, BERKSHIRE  
RG41 3HW, ENGLAND UNITED KINGDOM  
Tel: 44-118-978 3978 Fax: 44-118-977 5261

REGIONAL OFFICE :

**SEAGULL SAFETY (S) PTE LTD**

1 GENTING LINK  
#07-06 PERFECT INDUSTRIAL BUILDING  
SINGAPORE 349518  
Tel: (65) 6-747 9646 Fax: (65) 6-744 4028

TITLE :

**STANDARD 19" CARD RACK**

**SS814 - R**

**REAR TERMINAL DETAILS**

| REV. | DATE     | DESCRIPTION               | DRAWN | CHECK'D |
|------|----------|---------------------------|-------|---------|
| 0    | 11.12.92 | ISSUED FOR APPROVAL       | SA    | AD      |
| 1    | 24.07.98 | REVISED DETAIL TRK & DATA | SA    | AD      |

THIS IS THE PROPERTY OF SEAGULL SAFETY LTD AND IS ONLY ISSUED ON CONDITION THAT NO COPY IS TAKEN OR REPRODUCTION OR DISCLOSURE TO A THIRD PARTY EITHER WHOLLY OR IN PART IS MADE WITHOUT THE WRITTEN CONSENT OF SEAGULL SAFETY LTD.

|             |                         |      |            |
|-------------|-------------------------|------|------------|
| DESIGNED BY | SA                      | DATE | 11.12.1992 |
| CHECKED BY  | AD                      | DATE | 11.12.1992 |
| DWG NO :    | SS66100-12 (SHT 2 OF 2) |      |            |
| REVISION    | 1                       |      |            |