


FRONT VIEW



SIDE VIEW

CONTROL PANEL

TYPE

RITTAL EL 2256 C/W
WALL PART INCLUDING 2 CABLE GLAND PLATES,
HINGED PART INCLUDING 2 FITTED 19 INCH
MOUNTING ANGLES, FRONT DOOR, MOUNTING
PLATE AND MOUNTING MATERIAL.

MATERIAL

WALL PART AND HINGED PART 1.5mm SHEET STEEL

FRONT DOOR :
EXTRUDED ALUMINIUM SECTION/CORNER CONNECTOR
OF DIECAST ALUMINIUM
4mm SECURITY GLASS

MOUNTING PLATE :
2.75mm SHEET STEEL

SURFACE FINISH

ELECTROPHORETIC DIPCOAT PRIMING,
TEXTURED STOVE ENAMELLING
ENCLOSURE RAL 7032
DOOR FRAME RAL 7033

PROTECTIVE CATAGORY

IP 55 TO EN 60 529/10.91

DESCRIPTION

SS814 19" RACKS MOUNTED ON HINGED SECTION GIVING EASY
ACCESS TO REAR OF RACKS

WIRING FROM RACKS WILL BE LOOMED TO SAK 2.5 INPUT/
OUTPUT TERMINALS LOCATED ON MOUNTING PLATE.
WIRING WILL BE RUN IN TRUNKING AND WILL BE FITTED WITH
WIRE MARKERS CORRESPONDING TO NUMBERS ON SCHEMATIC
DIAGRAM. EACH WIRE WILL BE TERMINATED IN AN INSULATED
CRIMP TERMINAL. THE POWER SUPPLY TO EACH RACK IS
CONTROLLED BY A DEDICATED MINIATURE CIRCUIT BREAKER.
ALL SYSTEM ANCILLARY COMPONENTS WILL BE DIN RAIL
MOUNTED WHEREVER POSSIBLE.

REV.	DATE	DESCRIPTION	DRAWN	CHK'D
0	24.07.98	REVISED T&K	S.A.	
0	01.07.99	ISSUED FOR APPROVAL	S.A.	



HEAD OFFICE :
SEAGULL SAFETY LTD
45 CHESTNUT AVENUE
WOKINGHAM, BERKSHIRE
RG41 3HW, ENGLAND UNITED KINGDOM
Tel: 44-118-978 3978 Fax: 44-118-977 5261

REGIONAL OFFICE :
SEAGULL SAFETY (S) PTE LTD
1 GENTING LINK
#07-06 PERFECT INDUSTRIAL BUILDING
SINGAPORE 349518
Tel: (65) 747 9646 Fax: (65) 744 4028

TITLE :		3-PART WALL MOUNTED CONTROL PANEL FOR 19 INCH RACK (SS814GD/M & SS814AN-1)	
DRAWN BY	SA	DATE:	01.07.1993
CHECKED BY		DATE:	
DRWG NO :	SS66100-20		REVISION
			1

THIS IS THE PROPERTY OF SEAGULL SAFETY LTD AND IS ONLY ISSUED ON CONDITION THAT NO COPY IS TAKEN OR REPRODUCTION OR DISCLOSURE TO A THIRD PARTY EITHER WHOLLY OR IN PART IS MADE WITHOUT THE WRITTEN CONSENT OF SEAGULL SAFETY LTD.

REV. 3/1 (25.08.1998) P. S. 11-4.3 #CAD REF SS661-20