



CONTROL PANEL

TYPE

RITLAL EL 2265 C/W WALL PART INCLUDING 2 CABLE GLAND PLATES, HINGED PART INCLUDING 2 FITTED 19 INCH MOUNTING ANGLES FRONT DOOR MOUNTING PLATE AND MOUNTING MATERIAL.

MATERIAL
WALL PART AND HINGED PART 1.5mm SHEET STEEL

FRONT ELEVATION

FRONT DOOR

EXTRUDED ALUMINIUM SECTION/
CORNER CONNECTOR OF DIECAST ALUMINIUM
4mm SECURITY GLASS
MOUNTING PLATE
2.75mm SHEET STEEL

SURFACE

ELECTROPHORETIC DIPCOAT
PRIMING, TEXTURED STOVE ENAMELLING
ENCLOSURE RAL 7032
DOOR FRAME RAL 7032
PROTECTIVE CATAGORY
IP55 TO EN 60 529/10.91

SIDE ELEVATION

DESCRIPTION

SS814 19" RACKS MOUNTED ON HINGED SECTION GIVING EASY ACCESS TO REAR OF RACKS.
WIRING FROM RACKS WILL BE LOOMED TO SAK 2.5 INPUT/ OUTPUT TERMINALS LOCATED ON MOUNTING PLATE. WIRING WILL BE RUN IN TRUNKING AND WILL BE FITTED WITH WIRE MARKERS CORRESPONDING TO NUMBERS ON SCHEMATIC DIAGRAM. EACH WIRE WILL BE TERMINATED IN AN INSULATED CRIMP TERMINAL. THE POWER SUPPLY TO EACH RACK IS CONTROLLED BY A DEDICATED MINIATURE CIRCUIT BREAKER. ALL SYSTEM ANCLILARY COMPONENTS WILL BE DIN RAIL MOUNTED WHEREVER POSSIBLE.

REV.	DATE	DESCRIPTION	DRAWN	CHECK'D
0	01.07.93	ISSUED FOR APPROVAL	S.A	
1	24.07.98	REVISED PANEL SIZE & TRK	S.A	



SEAGULL SAFETY LTD
45 CHESTNUT AVENUE
WOKINGHAM, BERKSHIRE
RG41 3HW, ENGLAND UNITED KINGDOM
Tel: 44-118-978 3978 Fax: 44-118-977 5261

SEAGULL SAFETY (S) PTE LTD
1 GENTING LINK
PERFECT INDUSTRIAL BUILDING
SINGAPORE 349518
Tel: (65) 747 9646 Fax: (65) 744 4028

THIS IS THE PROPERTY OF SEAGULL SAFETY LTD AND IS ONLY ISSUED ON CONDITION THAT NO COPY IS TAKEN OR REPRODUCTION OR DISCLOSURE TO A THIRD PARTY EITHER WHOLLY OR IN PART IS MADE WITHOUT THE WRITTEN CONSENT OF SEAGULL SAFETY LTD.

TITLE :

3-PART WALL MOUNTED CONTROL PANEL FOR 3 Nos 19 INCH RACKS (TYPICAL)

DRAWN BY	SA	DATE	01.07.1993
CHECKED BY		DATE	
DWG NO :	SS66100-22		
REVISION	1		