


FRONT VIEW



SIDE VIEW

CONTROL PANEL

TYPE

RITTAL EL 2262 C/W WALL PART INCLUDING 2 CABLE GLAND PLATES, HINGED PART INCLUDING 2 FITTED 19 INCH MOUNTING ANGLES FRONT DOOR, MOUNTING PLATE AND MOUNTING MATERIAL.

MATERIAL

WALL PART AND HINGED PART  
1.5mm SHEET STEEL

FRONT DOOR :  
EXTRUDED ALUMINIUM SECTION/  
CORNER CONNECTOR OF DIECAST ALUMINIUM  
4mm SECURITY GLASS

MOUNTING PLATE  
2.75mm SHEET STEEL

SURFACE FINISH

ELECTROPHORETIC DIPCOAT  
PRIMING, TEXTURED STOVE ENAMELLING

ENCLOSURE RAL 7032  
DOOR FRAME RAL 7033

PROTECTIVE CATAGORY

IP55 TO EN 60 529/10.91

DESCRIPTION

SS814 19" RACKS MOUNTED ON HINGED SECTION GIVING EASY ACCESS TO REAR OF RACKS.

WIRING FROM RACKS WILL BE LOOMED TO SAK 2.5 INPUT/ OUTPUT TERMINALS LOCATED ON MOUNTING PLATE. WIRING WILL BE RUN IN TRUNKING AND WILL BE FITTED WITH WIRE MARKERS CORRESPONDING TO NUMBERS ON SCHEMATIC DIAGRAM. EACH WIRE WILL BE TERMINATED IN AN INSULATED CRIMP TERMINAL. THE POWER SUPPLY TO EACH RACK IS CONTROLLED BY A DEDICATED MINIATURE CIRCUIT BREAKER. ALL SYSTEM ANCILLARY COMPONENTS WILL BE DIN RAIL MOUNTED WHEREVER POSSIBLE.

1	21.07.98	REVISED PANEL SIZE & TBK	S. A.
0	01.07.93	ISSUED FOR APPROVAL	S. A.
REV.	DATE	DESCRIPTION	DRAWN CHCK'D

 <b>SEAGULL SAFETY LTD</b> 45 CHESTNUT AVENUE WOKINGHAM, BERKSHIRE RG41 3HW, ENGLAND UNITED KINGDOM Tel: 44-118-978 3978 Fax: 44-118-977 5261	REGIONAL OFFICE : <b>SEAGULL SAFETY (S) PTE LTD</b> 1 GENTING LINK #07-06 PERFECT INDUSTRIAL BUILDING SINGAPORE 349518 Tel: (65) 747 9646 Fax: (65) 744 4028
---	---

TITLE : <b>3-PART WALL MOUNTED CONTROL PANEL FOR 2 Nos19 INCH RACKS (TYPICAL)</b>	
DRAWN BY : SA	DATE : 01.07.1993
CHECKED BY :	DATE :
DRWG NO : <b>SS66100-21</b>	REVISION <b>1</b>

THIS IS THE PROPERTY OF SEAGULL SAFETY LTD AND IS ONLY ISSUED ON CONDITION THAT NO COPY IS TAKEN OR REPRODUCTION OR DISCLOSURE TO A THIRD PARTY EITHER WHOLLY OR IN PART IS MADE WITHOUT THE WRITTEN CONSENT OF SEAGULL SAFETY LTD.

REV. 2/1 (17.08.1990) P.S. 1-5 A4/AD REF. SS661-21